

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X10		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	x Average	o Colder	o Warmer
Temperature application	x Medium (55°C)	o Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	8	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	7.0	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 2°C	Pdh	6.8	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 7°C	Pdh	7.3	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 12°C	Pdh	9.5	kW
Degradation co-efficient	Cdh	0.98	-
Tj = bivalent temperature	Pdh	7.0	kW
Tj = operation limit temperature	Pdh	10.0	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW
Bivalent temperature	Tbiv	-7	°C
Cycling interval capacity for heating	Pcych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.025	kW
Crankcase heater mode	PCK	0.000	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/69	dB
Annual energy consumption	QHE	5070	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	126	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	2.11	-
Tj = + 2°C	COPd	3.06	-
Tj = + 7°C	COPd	4.25	-
Tj = + 12°C	COPd	6.50	-
Tj = bivalent temperature	COPd	2.11	-
Tj = operation limit temperature	COPd	1.78	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details

Fondital S.p.A
Via Cerreto 40, 25079 Vobarno (BS) - Italy

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X10		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	o Average	x Colder	o Warmer
Temperature application	x Medium (55°C)	o Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	7	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	6.0	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 2°C	Pdh	6.0	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 7°C	Pdh	7.4	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 12°C	Pdh	9.7	kW
Degradation co-efficient	Cdh	0.99	-
Tj = bivalent temperature	Pdh	6.0	kW
Tj = operation limit temperature	Pdh	8.0	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	6.0	kW
Bivalent temperature	Tbiv	-15	°C
Cycling interval capacity for heating	Pcych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.025	kW
Crankcase heater mode	PCK	0.000	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/69	dB
Annual energy consumption	QHE	6800	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	104	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	2.09	-
Tj = + 2°C	COPd	2.99	-
Tj = + 7°C	COPd	4.66	-
Tj = + 12°C	COPd	6.96	-
Tj = bivalent temperature	COPd	2.01	-
Tj = operation limit temperature	COPd	1.51	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	2.00	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)				PROCIDA AWM X10			
Air-to-water heat pump	x Yes	o No					
Water-to-water heat pump	o Yes	x No					
Brine-to-water heat pump	o Yes	x No					
Low-temperature heat pump	o Yes	x No					
Equipped with a supplementary heater	o Yes	x No					
Heat pump combination heater	o Yes	x No					
Climate conditions	o Average		o Colder		x Warmer		
Temperature application	x Medium (55°C)		o Low (35°C)				
Applied Standards	EN14825						

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output	Prated	8	kW	Seasonal space heating energy efficiency	η_s	150	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj	Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj						
Tj = - 7°C	Pdh	-	kW	Tj = - 7°C	COPd	-	-
Degradation co-efficient	Cdh	-	-	Tj = + 2°C	COPd	2.27	-
Tj = + 2°C	Pdh	7.8	kW	Tj = + 7°C	COPd	2.97	-
Degradation co-efficient	Cdh	0.99	-	Tj = + 12°C	COPd	5.52	-
Tj = + 7°C	Pdh	6.5	kW	Tj = bivalent temperature	COPd	2.27	-
Degradation co-efficient	Cdh	0.99	-	Tj = operation limit temperature	COPd	2.24	-
Tj = + 12°C	Pdh	9.5	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Degradation co-efficient	Cdh	0.98	-	Operation limit temperature	TOL	-25	°C
Tj = bivalent temperature	Pdh	7.8	kW	Cycling interval efficiency	COPcyc	-	-
Tj = operation limit temperature	Pdh	7.8	kW	Heating water operating limit temperature	WTOL	60	°C
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW				
Bivalent temperature	Tbiv	2	°C				
Cycling interval capacity for heating	Pcyc	-	kW				

Power consumption in modes other than active mode				Supplementary heater			
Off mode	POFF	0.025	kW	Rated heat output	Psup	-	kW
Thermostat-off mode	PTO	0.025	kW	Type of energy input	-		
Standby mode	PSB	0.025	kW				
Crankcase heater mode	PCK	0.000	kW				

Other items							
Capacity control	variable			Rated air flow rate, outdoors	-	4500	m3/h
Sound power level, indoors/ outdoors	LWA	-/69	dB	Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h
Annual energy consumption	QHE	2723	kWh				

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy		
-----------------	--	--	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X10		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	x Average	o Colder	o Warmer
Temperature application	o Medium (55°C)	x Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	9	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	8.2	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 2°C	Pdh	5.0	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 7°C	Pdh	7.7	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 12°C	Pdh	9.6	kW
Degradation co-efficient	Cdh	0.97	-
Tj = bivalent temperature	Pdh	8.2	kW
Tj = operation limit temperature	Pdh	10.8	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW
Bivalent temperature	Tbiv	-7	°C
Cycling interval capacity for heating	Pcyh	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.025	kW
Crankcase heater mode	PCK	0.010	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/69	dB
Annual energy consumption	QHE	4235	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	177	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	3.12	-
Tj = + 2°C	COPd	4.25	-
Tj = + 7°C	COPd	5.82	-
Tj = + 12°C	COPd	8.21	-
Tj = bivalent temperature	COPd	3.12	-
Tj = operation limit temperature	COPd	2.42	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m ³ /h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m ³ /h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)		PROCIDA AWM X10			
Air-to-water heat pump	x Yes	o No			
Water-to-water heat pump	o Yes	x No			
Brine-to-water heat pump	o Yes	x No			
Low-temperature heat pump	o Yes	x No			
Equipped with a supplementary heater	o Yes	x No			
Heat pump combination heater	o Yes	x No			
Climate conditions	o Average	x Colder		o Warmer	
Temperature application	o Medium (55°C)	x Low (35°C)			
Applied Standards	EN14825				

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output	Prated	7	kW	Seasonal space heating energy efficiency	η_s	143	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	5.7	kW	Tj = - 7°C	COPd	3.13	-
Degradation co-efficient	Cdh	0.99	-	Tj = + 2°C	COPd	4.22	-
Tj = + 2°C	Pdh	4.5	kW	Tj = + 7°C	COPd	5.93	-
Degradation co-efficient	Cdh	0.98	-	Tj = + 12°C	COPd	8.26	-
Tj = + 7°C	Pdh	7.8	kW	Tj = bivalent temperature	COPd	2.21	-
Degradation co-efficient	Cdh	0.98	-	Tj = operation limit temperature	COPd	2.01	-
Tj = + 12°C	Pdh	9.8	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	2.21	-
Degradation co-efficient	Cdh	0.98	-	Operation limit temperature	TOL	-25	°C
Tj = bivalent temperature	Pdh	5.4	kW	Cycling interval efficiency	COPcyc	-	-
Tj = operation limit temperature	Pdh	9.2	kW	Heating water operating limit temperature	WTOL	60	°C
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	5.4	kW				
Bivalent temperature	Tbiv	-15	°C				
Cycling interval capacity for heating	Pcyc	-	kW				

Power consumption in modes other than active mode				Supplementary heater			
Off mode	POFF	0.025	kW	Rated heat output	Psup	-	kW
Thermostat-off mode	PTO	0.025	kW	Type of energy input	-		
Standby mode	PSB	0.020	kW				
Crankcase heater mode	PCK	0.000	kW				

Other items				Rated air flow rate, outdoors			
Capacity control	variable			-	4500	m3/h	
Sound power level, indoors/ outdoors	LWA	-/69	dB	Rated brine or water flow rate, outdoor heat exchanger			
Annual energy consumption	QHE	4480	kWh	-	-	m3/h	

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy		
-----------------	--	--	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X10		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	o Average	o Colder	x Warmer
Temperature application	o Medium (55°C)	x Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	10	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	-	kW
Degradation co-efficient	Cdh	-	-
Tj = + 2°C	Pdh	9.5	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 7°C	Pdh	8.4	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 12°C	Pdh	9.6	kW
Degradation co-efficient	Cdh	0.97	-
Tj = bivalent temperature	Pdh	9.5	kW
Tj = operation limit temperature	Pdh	9.5	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW
Bivalent temperature	Tbiv	2	°C
Cycling interval capacity for heating	Ppsych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.020	kW
Crankcase heater mode	PCK	0.000	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/69	dB
Annual energy consumption	QHE	2201	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	228	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	-	-
Tj = + 2°C	COPd	3.34	-
Tj = + 7°C	COPd	5.10	-
Tj = + 12°C	COPd	7.39	-
Tj = bivalent temperature	COPd	3.34	-
Tj = operation limit temperature	COPd	3.34	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--