

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)		PROCIDA AWM X14			
Air-to-water heat pump	x Yes	o No			
Water-to-water heat pump	o Yes	x No			
Brine-to-water heat pump	o Yes	x No			
Low-temperature heat pump	o Yes	x No			
Equipped with a supplementary heater	o Yes	x No			
Heat pump combination heater	o Yes	x No			
Climate conditions	x Average	o Colder		o Warmer	
Temperature application	x Medium (55°C)	o Low (35°C)			
Applied Standards	EN14825				

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated heat output	Prated	11	kW	Seasonal space heating energy efficiency	ηs	125	%
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	9.8	kW	Tj = - 7°C	COPd	1.92	-
Degradation co-efficient	Cdh	0.99	-	Tj = + 2°C	COPd	3.06	-
Tj = + 2°C	Pdh	6.8	kW	Tj = + 7°C	COPd	4.25	-
Degradation co-efficient	Cdh	0.99	-	Tj = + 12°C	COPd	6.50	-
Tj = + 7°C	Pdh	7.3	kW	Tj = bivalent temperature	COPd	1.92	-
Degradation co-efficient	Cdh	0.99	-	Tj = operation limit temperature	COPd	1.78	-
Tj = + 12°C	Pdh	9.5	kW	Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Degradation co-efficient	Cdh	0.98	-	Operation limit temperature	TOL	-25	°C
Tj = bivalent temperature	Pdh	9.8	kW	Cycling interval efficiency	COPcyc	-	-
Tj = operation limit temperature	Pdh	10.0	kW	Heating water operating limit temperature	WTOL	60	°C
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW				
Bivalent temperature	Tbiv	-7	°C				
Cycling interval capacity for heating	Pcyc	-	kW				

Power consumption in modes other than active mode				Supplementary heater			
Off mode	POFF	0.025	kW	Rated heat output	Psup	-	kW
Thermostat-off mode	PTO	0.025	kW	Type of energy input	-		
Standby mode	PSB	0.020	kW				
Crankcase heater mode	PCK	0.000	kW				

Other items				Other items			
Capacity control	variable			Rated air flow rate, outdoors	-	4500	m3/h
Sound power level, indoors/ outdoors	LWA	-/70	dB	Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h
Annual energy consumption	QHE	7213	kWh				

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X14		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	o Average	x Colder	o Warmer
Temperature application	x Medium (55°C)	o Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	10	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	6.9	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 2°C	Pdh	6.0	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 7°C	Pdh	7.4	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 12°C	Pdh	9.7	kW
Degradation co-efficient	Cdh	0.99	-
Tj = bivalent temperature	Pdh	7.9	kW
Tj = operation limit temperature	Pdh	8.0	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	7.9	kW
Bivalent temperature	Tbiv	-15	°C
Cycling interval capacity for heating	Pcych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.020	kW
Crankcase heater mode	PCK	0.000	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/70	dB
Annual energy consumption	QHE	8967	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	103	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	2.11	-
Tj = + 2°C	COPd	2.99	-
Tj = + 7°C	COPd	4.66	-
Tj = + 12°C	COPd	6.96	-
Tj = bivalent temperature	COPd	1.83	-
Tj = operation limit temperature	COPd	1.51	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	1.83	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X14		
Air-to-water heat pump	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Water-to-water heat pump	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Brine-to-water heat pump	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Low-temperature heat pump	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Equipped with a supplementary heater	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Heat pump combination heater	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	
Climate conditions	<input type="checkbox"/> Average	<input type="checkbox"/> Colder	<input checked="" type="checkbox"/> Warmer
Temperature application	<input checked="" type="checkbox"/> Medium (55°C)	<input type="checkbox"/> Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	8	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	-	kW
Degradation co-efficient	Cdh	-	-
Tj = + 2°C	Pdh	7.8	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 7°C	Pdh	6.5	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 12°C	Pdh	9.5	kW
Degradation co-efficient	Cdh	0.98	-
Tj = bivalent temperature	Pdh	7.8	kW
Tj = operation limit temperature	Pdh	7.8	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW
Bivalent temperature	Tbiv	2	°C
Cycling interval capacity for heating	Pcych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.020	kW
Crankcase heater mode	PCK	0.000	kW

Other items			
Capacity control		variable	
Sound power level, indoors/ outdoors	LWA	-/70	dB
Annual energy consumption	QHE	2723	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	150	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	-	-
Tj = + 2°C	COPd	2.27	-
Tj = + 7°C	COPd	2.97	-
Tj = + 12°C	COPd	5.52	-
Tj = bivalent temperature	COPd	2.27	-
Tj = operation limit temperature	COPd	2.27	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input		-	

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X14		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	x Average	o Colder	o Warmer
Temperature application	o Medium (55°C)	x Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	11	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	10.1	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 2°C	Pdh	6.2	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 7°C	Pdh	7.7	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 12°C	Pdh	9.6	kW
Degradation co-efficient	Cdh	0.97	-
Tj = bivalent temperature	Pdh	10.1	kW
Tj = operation limit temperature	Pdh	10.8	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW
Bivalent temperature	Tbiv	-7	°C
Cycling interval capacity for heating	Pcyc	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.020	kW
Crankcase heater mode	PCK	0.010	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/70	dB
Annual energy consumption	QHE	5468	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	170	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	2.84	-
Tj = + 2°C	COPd	4.04	-
Tj = + 7°C	COPd	5.82	-
Tj = + 12°C	COPd	8.21	-
Tj = bivalent temperature	COPd	2.84	-
Tj = operation limit temperature	COPd	2.42	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X14		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	o Average	x Colder	o Warmer
Temperature application	o Medium (55°C)	x Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	9	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	7.1	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 2°C	Pdh	5.6	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 7°C	Pdh	7.8	kW
Degradation co-efficient	Cdh	0.97	-
Tj = + 12°C	Pdh	9.8	kW
Degradation co-efficient	Cdh	0.97	-
Tj = bivalent temperature	Pdh	7.6	kW
Tj = operation limit temperature	Pdh	9.2	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	7.6	kW
Bivalent temperature	Tbiv	-15	°C
Cycling interval capacity for heating	Pcych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.020	kW
Crankcase heater mode	PCK	0.000	kW

Other items			
Capacity control		variable	
Sound power level, indoors/ outdoors	LWA	-/70	dB
Annual energy consumption	QHE	6475	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	138	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	2.93	-
Tj = + 2°C	COPd	4.05	-
Tj = + 7°C	COPd	5.93	-
Tj = + 12°C	COPd	8.26	-
Tj = bivalent temperature	COPd	2.21	-
Tj = operation limit temperature	COPd	2.01	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	2.21	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input		-	

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--

COMMISSION REGULATION (EU) No 813/2013 of 2 August 2013 implementing Directive 2009/125/EC of the European Parliament and of the Council with regard to ecodesign requirements for space heaters and combination heaters. ANNEX II, point 5, Table 2.

COMMISSION DELEGATED REGULATION (EU) No 811/2013 of 18 February 2013 supplementing Directive 2010/30/EU of the European Parliament and of the Council with regard to the energy labelling of space heaters, combination heaters, packages of space heater, temperature control and solar device and packages of combination heater, temperature control and solar device. ANNEX V, Table 8.

Model(s)	PROCIDA AWM X14		
Air-to-water heat pump	x Yes	o No	
Water-to-water heat pump	o Yes	x No	
Brine-to-water heat pump	o Yes	x No	
Low-temperature heat pump	o Yes	x No	
Equipped with a supplementary heater	o Yes	x No	
Heat pump combination heater	o Yes	x No	
Climate conditions	o Average	o Colder	x Warmer
Temperature application	o Medium (55°C)	x Low (35°C)	
Applied Standards	EN14825		

Item	Symbol	Value	Unit
Rated heat output	Prated	12	kW
Declared capacity for heating for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	Pdh	-	kW
Degradation co-efficient	Cdh	-	-
Tj = + 2°C	Pdh	11.8	kW
Degradation co-efficient	Cdh	0.99	-
Tj = + 7°C	Pdh	8.4	kW
Degradation co-efficient	Cdh	0.98	-
Tj = + 12°C	Pdh	9.6	kW
Degradation co-efficient	Cdh	0.97	-
Tj = bivalent temperature	Pdh	11.8	kW
Tj = operation limit temperature	Pdh	11.8	kW
Tj = - 15 °C (if TOL < - 20 °C)	Pdh	-	kW
Bivalent temperature	Tbiv	2	°C
Cycling interval capacity for heating	Pcych	-	kW

Power consumption in modes other than active mode			
Off mode	POFF	0.025	kW
Thermostat-off mode	PTO	0.025	kW
Standby mode	PSB	0.025	kW
Crankcase heater mode	PCK	0.025	kW

Other items			
Capacity control	variable		
Sound power level, indoors/ outdoors	LWA	-/70	dB
Annual energy consumption	QHE	2721	kWh

Item	Symbol	Value	Unit
Seasonal space heating energy efficiency	ηs	228	%
Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7°C	COPd	-	-
Tj = + 2°C	COPd	3.14	-
Tj = + 7°C	COPd	5.10	-
Tj = + 12°C	COPd	7.39	-
Tj = bivalent temperature	COPd	3.14	-
Tj = operation limit temperature	COPd	3.14	-
Tj = - 15 °C (if TOL < - 20 °C)	COPd	-	-
Operation limit temperature	TOL	-25	°C
Cycling interval efficiency	COPcyc	-	-
Heating water operating limit temperature	WTOL	60	°C

Supplementary heater			
Rated heat output	Psup	-	kW
Type of energy input	-		

Rated air flow rate, outdoors	-	4500	m3/h
Rated brine or water flow rate, outdoor heat exchanger	-	-	m3/h

Contact details	Fondital S.p.A Via Cerreto 40, 25079 Vobarno (BS) - Italy
-----------------	--